

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com


TEST REPORT			
Name & Address of Customer : Principal Modern High School Mata Kaulan Marg, The Mall, Amritsar		Customer Reference No.	No : Nil Dated : 15/04/2024
		Sample Submitted by	Mr.Surinder Singh
		Date of Sample Receipt	16/04/2024
		Analysis Starting Date	18/04/2024
		Analysis completion Date	19/04/2024
Discipline : Chemical Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	RWTLASR/2425/00040	Date of Issue :	23/04/2024
Registration no.:	RWTLASR/REG2425/00673	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	The Mall(S/pump 350 ft) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Amritsar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.15@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	505	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	0.58@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	Alkalinity	360	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	Hardness	320	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
8	Calcium	67.33	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	36.93	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	41.98	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By




Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar

----- End of the Test Report -----



Attested
Principal
Modern High School
Mata Kaula Marg, (The Mall)
Amritsar. (Aff. No. 1630550)



Manager/Director
Modern High School
Mata Kaulan Marg, The Mall
Amritsar



mohmear@gmail.com




ਦਫਤਰ ਸਿਹਤ ਵਿਭਾਗ ਨਗਰ ਨਿਗਮ, ਅੰਮ੍ਰਿਤਸਰ।

ਨੰ: ਐਚ/11

ਮਿਤੀ/ 16-4-24


Subject: No Objection Certificate

MODERN HIGH SCHOOL, AMRITSAR MATA KAULAN MARG,
THE MALL, AMRITSAR ਮਿਤੀ 16/04/2024 ਦੇ ਸਬੰਧ ਵਿਚ ਸੈਨੇਟਰੀ ਇੰਸਪੈਕਟਰ/ਚੀਫ ਸੈਨੇਟਰੀ
ਇੰਸਪੈਕਟਰ ਦੀ ਰਿਪੋਰਟ ਮੁਤਾਬਕ ਮੇਕੇ ਉਪਰ MODERN HIGH SCHOOL, AMRITSAR ਸੈਨੀਟੇਸ਼ਨ
ਦੇ ਲਿਹਾਜ਼ ਨਾਲ ਬਹੁਤ ਵਧੀਆ ਹੈ। ਇਸ ਲਈ ਸਾਲ 2024-2025 ਲਈ ਇਤਰਾਜ਼ਹੀਣਤਾ ਸਰਟੀਫਿਕੇਟ
ਦਿੱਤਾ ਜਾਂਦਾ ਹੈ।


16/4/24
ਸਿਹਤ ਅਫਸਰ
ਨਗਰ ਨਿਗਮ, ਅੰਮ੍ਰਿਤਸਰ।



Attested
Principal
Modern High School
Mata Kaula Marg, (The Mall)
Amritsar. (Aff. No. 1630550)



Manager/Director
Modern High School
Mata Kaula Marg, The Mall
Amritsar